

Case Type

Full Height Glass Door

Model Designation

FD3

File Reference

1119

Document Issue

1	28.10.09	GR	First Issue
2	01.12.09	IG	Defrost termination revised evap coil only
3	18.01.10	AG	5DR Lighting Load
4	29.05.12	LRC	Defrost number changed

cabinet **TECHNICAL DATA**

Cabinet Technical Data Sheet – FD3

Product Type	Frozen Food / 3L1
Product Temperature	-18°C
Maximum Design Ambient	25°C @ 60%RH

Case Length [m]	5 Dr (3.90)	4 Dr (3.12)	3 Dr (2.34)	2 Dr (1.56)
-----------------	-------------	-------------	-------------	-------------

Refrigeration Data

Refrigeration Duty (per 24hrs) [kW]	2.53	2.02	1.52	1.02
Evaporating Temperature [°C]	-32	-32	-32	-32
R744 AKV Expansion Valve Size	No3	No2	No2	No1
Evaporator Liquid Capacity @ 90% R744 [kg]	TBC	TBC	TBC	TBC
Refrigeration Pipe Tail – Liquid	3/8"	3/8"	3/8"	3/8"
Refrigeration Pipe Tail – Suction	3/8"	3/8"	3/8"	3/8"

Electrical Data (@ 230V 50Hz)

	Watts	Amps	Watts	Amps	Watts	Amps	Watts	Amps
Defrost Heaters	4900	21.3	3800	16.5	2750	11.9	1700	7.4
Fans (EC EBM)	35	0.15	28	0.12	21	0.09	14	0.06
Trim Heaters (Max)	1325	5.76	1050	4.57	680	2.96	550	2.39
Solenoid Valve / Controller	10	0.04	10	0.04	10	0.04	10	0.04
Lights (T5)	380	1.65	305	1.33	228	0.99	152	0.66
Maximum Load – Electric Defrost	6650	28.9	5193	22.6	3689	16.0	2426	10.6

Electrical Data (@400V 3ph 50Hz)

	L1	L2	L3	L1	L2	L3	L1	L2	L3	L1	L2	L3
Maximum Load – Electric Defrost	8	11	11	6.5	8.5	8.5	4.5	6	6	3.5	4	4

Miscellaneous Data


Refrigeration Connections	Underside of Cabinet LHS
Electrical Connection	Underside of Cabinet LHS

Set-Up Data**

	Electric Defrost
Cut in Temperature [°C]	-22
Differential [K]	2
N° Defrosts (per 24hrs)	2
Maximum Defrost Time [mins]	60
Defrost Termination Temp (coil probe) [°C]	1
Drain Down Time [mins]	2
Fans in Defrost (slow speed in defrost)	OFF
Cabinet Temperature Ratio (%)	50
Superheat [K]	4
Temp to Turn Fan ON After Defrost [°C]	-15
Time to Turn Fan ON After Defrost [min]	10

NOTES! ** Set-up data is for guidance only. Final settings to be determined by commissioning contractor.
 *** If End Case ADD 143W (0.62A) per Cabinet for End Glazed units only.


Section Drawing – FD3



Ref:- DS1099-02

Plan Drawing – FD3

- KEY
- Feet Positions
 - Refrig. Outlet
 - ◐ Drain Outlet
 - ⊗ Elect. Outlet
 - ⊗ Mains Supply



Plan of Base

Ref:- DP1099-02